

CERTIFICATE

Issued to:
Applicant:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Manufacturer/Licensee:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Product(s) : socket-outlets of the series A, B, C, D, E and G
Trade name(s) : NIKO
Type(s)/model(s) : -3.1/***-65701/-, -3.1/***-65801/-, -3.1/***-66201/-, -3.1/***-66501/-, -3.1/***-66801/-,
-3.1/***-66901/-, -3.3/***-65701/-, -3.3/***-65801/-, -3.3/***-66201/-, -3.3/***-66501/-,
-3.3/***-66801/-, -3.3/***-66901/-

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard IEC 60884-1:2002 + A1: 2006 + A2: 2013, NEN 1020:1987 + A2: 2004
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900367

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 3 April 2015 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2181988.01

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



H.L. Schendstok
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	:	socket-outlets of the series A, B, C, D, E and G
trade name	:	NIKO
types	:	-3.1/***-65701/-, -3.1/***-65801/-, -3.1/***-66201/-, -3.1/***-66501/-, -3.1/***-66801/-, -3.1/***-66901/-, -3.3/***-65701/-, -3.3/***-65801/-, -3.3/***-66201/-, -3.3/***-66501/-, -3.3/***-66801/-, -3.3/***-66901/-
method of mounting	:	flush-type; screw-fixing
cover	:	plural cover plate
rated current	:	16 A
rated voltage	:	250 V~
earthing	:	with side earthing-contacts
markings	:	-tradename, series-indication and electrical rating on the base -tradename and suffix for the cover on this part

Additional information

The socket-outlets are intended to be used with the cover plates of the Series A, B, C, D, E or G

These covers have been constructed as follows:

Serie A

Duoshell (bottom shell: PC/ASA / top shell: Zamac; PC/ASA)

Serie B

Monoshell (PC-ASA)

Serie C

Duoshell (bottom shell: PC/ASA / top shell: inox, metal, forbo, plexi, aluminium, brass, PU+PA, PU)

Serie D

Duoshell (bottom shell: PC/ASA / top shell: bamboo, aluminium)

Serie E

Monoshell (PC-ASA)

Serie G

(PF, optional top shell: PU, resin+sand)

Product data - type -3.1/*-65701/-**

design : safety socket-outlet, provided with a lid
earthing : with side earthing-contacts
terminals : screw terminals

Product data - type -3.1/*-65801/-**

design : provided with a lid
earthing : with side earthing-contacts
terminals : screw terminals

Product data - type -3.1/*-66201/-**

earthing : without earthing contact
terminals : screw terminals

Product data - type -3.1/*-66501/-**

design : safety socket-outlet
earthing : without earthing contact
terminals : screw terminals

Product data - type -3.1/*-66801/-**

earthing : with side earthing-contacts
terminals : screw terminals

Product data - type -3.1/*-66901/-**

design : safety socket-outlet
earthing : with side earthing-contacts
terminals : screw terminals

Product data - type -3.3/*-65701/-**

design : safety socket-outlet, provided with a lid
earthing : with side earthing-contacts
terminals : screwless terminals

Product data - type -3.3/*-65801/-**

design : provided with a lid
earthing : with side earthing-contacts
terminals : screwless terminals

Product data - type -3.3/*-66201/-**

earthing : without earthing contact
terminals : screwless terminals

Product data - type -3.3/*-66501/-**

design : safety socket-outlet
earthing : without earthing contact
terminals : screwless terminals

Product data - type -3.3/*-66801/-**

earthing : with side earthing-contacts
terminals : screwless terminals

Product data - type -3.3/*-66901/-**

design : safety socket-outlet
earthing : with side earthing-contacts
terminals : screwless terminals

TESTS**Test requirements**

IEC 60884-1:2002 + A1:2006 + A2:2013
NEN 1020:1987 + A2:2004

Test result

The test results are laid down in DEKRA test file 2181988.01.

Remarks

This certificate replaces our certificate 2175350.01 dated 2015-01-15 and is also based on the SGS CEBEC CB-5959.

Conclusion

The examination proved that all test requirements were met.

Tested by : SGS CEBEC

Checked by : H.R.M. Barends

**Factory locations**

Niko N.V.
Industriepark West 40, 9100, Sint-Niklaas
Belgium